



5 Mile Pass Quarry
 801-616-5422
 Mile Marker 16 SR 73
 Fairfield, UT



A-1-b E-fill

Material Applications

Area Grading
 Trench Fill
 Other Fill Applications



Material Gradation

<u>Sieve Size</u>	<u>Requirement</u>	<u>Actual</u>	<u>Test Result</u>
3 inch	100 %	100 %	Pass
#40	< 50 %	39 %	Pass
#200	< 25 %	21.4 %	Pass

Material Proctor

Maximum Density: 135.3 *lbs/ft*³

Optimum Moisture: 7.1 %